

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0595:108 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Ansul Fire Protection, 1 Stanton St., Marinette, WI 54143
Contact: Lyle McDonald (715) 732-3601

DESIGN: Model "AutoPulse Four" local fire alarm control unit. Automatic, Manual, water flow, sprinkler supervisory and releasing device service. Refer to listee's data sheet for system detailed product description and operational considerations. Minimum configuration:

415413	Control Logic Assembly
415416	Power Supply Assembly
416610	Adder I/O Assembly
415414	Display Assembly
416611	Keypad Assembly

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a local fire alarm and releasing device control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

06-01-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 10, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager